



40'

40' CLASS 5 POLE

400 AMP 3 PHASE RISER PER CODE REQUIREMENTS

NEW 400 AMP FUSIBLE DISCONNECT SWITCH
NEW 100 AMP FUSIBLE DISCONNECT SWITCH

8" X 8" GUTTER
4" X 4" P.T. WOOD BACKBOARD

2- 2" SCH 40 PVC CONDUIT W/ PULL ROPE

2" PVC 40 W/ 4 #1 XHHW AL & 1 #8 CU GND

2" SCH 40 PVC CONDUIT W/ PULL ROPE

24 X 36 FIBERLITE POWER BOX

17 X 30 PHONE BOX

2" PVC 40 W/ 4 #1 XHHW AL & 1 #8 CU GND

TENSION GUY

30' CLASS 5 POLE

#1 TRIPLEX SERVICE WIRE

30' CLASS 5 POLE

#2 TRIPLEX SERVICE WIRE

TENSION GUY

30' CLASS 5 POLE

3/4" SCH 40 PVC W/ 3- #13 THHN CU & 1- #10 GNC.

WELL PUMP PANEL

NEW 100 AMP PANEL

HOUSE SUB PANEL

100 AMP RISER CONDUIT & CONDUCTORS

INTERCEPT AND REROUTE EXISTING CONDUIT AND CONDUCTORS